

www.eclipsenet.com

Applicationbrief

Eclipse Product: Flue Fire Burners

Submitted by: Leen Riedijk

Application: Supplemental Firing after gas engines

Site Location: Aceralia Corporacion Siderurgica S.A.–Aviles, Spain

System Description: The burner is designed to provide supplementary heat after 9 to 12 gas engines to one

common steam generator with the possibility for future extension to 16 engines. Due to the low oxygen content in the exhaust gas the burner is provided with a 100% primary combustion air supply. With the engines not in operation the burner can be fired in auxiliary air mode. The burner consists of 4 burner rows with 25 burner modules each and is suitable to fire natural gas, coke gas or a mixture of 80% steel gas and 20% natural gas. On order to obtain an optimal fuel gas distribution over the burner surface,

each row is provided with gas inlets at both sides.

Technical Data: Gas engines

Make GE-Jenbacher

Type J 600 GS

Engine exhaust gas

Flow 57.0 – 76.0 lb/s Oxygen level 8.68 vol% wet

Inlet temperature 985 °F Outlet temperature 1500 °C

Burner duty 37.5 MMBTU/h

Auxiliary air

Flow 52.8 lb/s Inlet temperature 59 °F Outlet temperature 1275 °F

Burner duty 61.4 MMBTU/h

Fuels

Natural gas LHV = 1010 BTU/scfh Coke gas LHV = 450 BTU/scfh Steel gas LHV = 235 BTU/scfh



Duct Burner prior to installation showing 4 rows of burner with supplemental air ducting.



www.eclipsenet.com